



# HOUSE COMMITTEE ON APPROPRIATIONS

## FISCAL NOTE

HOUSE BILL NO. 1171

PRINTER'S NO. 1236

PRIME SPONSOR: Hill-Evans

### COST / (SAVINGS)

FUND	FY 2022/23	FY 2023/24
General Fund	\$0	\$0

### SUMMARY:

House Bill 1171, Printer's Number 1236 changes the maximum distance that a fuel dispensing system can be from the master control emergency shut-off device.

### ANALYSIS:

The bill amends the Combustible and Flammable Liquids Act, which allows the Department of Labor and Industry to regulate combustible and flammable liquids like gasoline and diesel pumps to ensure safety.

The bill increases the maximum distance from a fuel pump to the master control emergency shut-off device from 200 feet to 350 feet.

The bill takes effect in 60 days.

### FISCAL IMPACT:

The bill would have no fiscal impact. The Department of Labor and Industry would continue to inspect fueling stations to ensure that they remain compliant with the change. Because the bill proposes to increase the minimum distance, it is presumed that current fueling stations would still be compliant. Therefore, the department would not need to re-inspect every location.

**PREPARED BY:** Eric Dice  
House Appropriations Committee (D)

**DATE:** June 22, 2023

*Estimates are calculated using the best information available. Actual costs and revenue impact incurred may vary from estimates.*